

Review of Utility Company Request for New Conduit/Pole Location

Applicant Information

Project Address

Utility
(Select one) Gas

Nicole Dr, Stewart St, Montview Ave,
Monadnock Ave, Pine St, Alyssa Dr, Raynor St

Reason Install both 2-inch and 4-inch, low pressure gas mains along Nicole Dr, Stewart St, Montview Ave, Monadnock Ave, Pine St, Alyssa Dr, Raynor St.

Date Submitted 11/16/2021

Review done by Daniel Lewis

Sidewalk Material Asphalt

Note: Sidewalk material to be replaced in kind (Concrete in full panels only)

Are Sidewalk Vaults present?

YES ☐ NO ☒

Is Work on Street under a Paving Moratorium?

YES ☒ NO ☐

Is this location within the Flood Plain?

YES ☐ NO ☒

Are ADA requirements being met?

YES ☒ NO ☐

Comments




Outlined portion of Princeton Blvd is State owned and was paved in 2019. Contact MassDOT for approval before starting any work. An approved Street Opening Permit will be required before starting any work on Nicole Dr, Stewart St, Montview Ave, Monadnock Ave, Pine St, Alyssa Dr, or Raynor St. Work on Nicole Dr will require ConCom approval due to proximity to wetland.

Outcome of Review Grant of location shall exclude Princeton Blvd (state owned).

Approved

Approved With
Comments

Denied



Ting Chang, P.E.
City Engineer